




The Huron Fire Department will be conducting all Transient Rental Inspections.

The application process will remain the same with applications submitted to the Planning and Zoning Department for processing and scheduling of your inspection

Reminder submit your complete renewal application with payment **at least 2-3 weeks** before your Certificate Expiration date

RECOMMENDATIONS & SUGGESTIONS....

While not currently required by the code, the Fire Department strongly recommends having Evacuation Plans posted on each door for the safety of your guests in the event of an emergency. This can be hand drawn or templates can be found online. This may be a requirement in the code in the future.



Something else to consider is the purchase of a Roperlock or Knoxbox; these boxes provide the Fire Department with access to your home and prevent property damage when trying to access the property in an emergency. We will be adding information on our Transient Rental and Fire Department website pages for these products as well as links to their websites. You can also contact the Fire Department for additional information and questions 419-433-5000 ext. 1610

**TRANSIENT RENTAL CODE
CHAPTER 1369**

**INSPECTION REMINDERS AND
INFO.....**

LABEL THE ELECTRICAL BOX,
PROPER WIRING

ELECTRICAL OUTLETS-
CHECKED FOR WORKING
CONDITION
*GFI OUTLETS REQUIRED
WITHIN 6' OF WATER SOURCES-
COMPLIANCE REQUIRED BY
2027 INSPECTION

FIRE EXTINGUISHERS- TYPE:
ABC *5LB- LOOK FOR " MIN.
2A10BC" (MEANS 5LB OF
CHEMICAL PRODUCT IN THE
EXTINGUISHER, NOT A 5LB
EXTINGUISHER)
EXTINGUISHERS MUST BE
WITHIN 6 YEARS OF
MANUFACTURED DATE.
COMPLIANCE REQUIRED
IF/WHEN THE 6 YR. DATE HAS
EXPIRED.

CHECK TO MAKE SURE SMOKE
AND CO DETECTORS ARE
WORKING & PROPERLY
LOCATED

BEDROOMS REQUIRE TWO
MEANS OF ACCESSIBLE INGRESS
& EGRESS
